Find an energy certificate (/)

English | Cymraeg

## **Energy performance certificate** (EPC)

34 Second Row Linton Colliery MORPETH	Energy rating	Valid until:	23 January 2032
NE61 5SQ		Certificate number:	2948-1011-5209-2962-0200

Property type	Mid-terrace house
Total floor area	71 square metres

## Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-privaterented-property-minimum-energy-efficiency-standard-landlord-guidance).

## **Energy rating and score**

This property's energy rating is C. It has the potential to be B.

See how to improve this property's energy efficiency.



The graph shows this property's current and potential energy rating.

**Properties get a rating from A (best) to G (worst) and a score.** The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

# Breakdown of property's energy performance

#### Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, filled cavity	Average
Roof	Pitched, 300 mm loft insulation	Very good
Window	Fully double glazed	Average
Main heating	Air source heat pump, radiators, electric	Good

Feature	Description	Rating
Main heating control	Programmer, TRVs and bypass	Average
Hot water	Electric immersion, off-peak	Average
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Suspended, no insulation (assumed)	N/A
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	None	N/A

#### Low and zero carbon energy sources

Low and zero carbon energy sources release very little or no CO2. Installing these sources may help reduce energy bills as well as cutting carbon emissions. The following low or zero carbon energy sources are installed in this property:

Air source heat pump

#### Primary energy use

The primary energy use for this property per year is 223 kilowatt hours per square metre (kWh/m2).

About primary energy use

## How this affects your energy bills

An average household would need to spend £822 per year on heating, hot water and lighting in this property. These costs usually make up the majority of your energy bills.

You could save £109 per year if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2022** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

#### Heating this property

Estimated energy needed in this property is:

- 9,612 kWh per year for heating
- 2,039 kWh per year for hot water

## Impact on the environment

This property's environmental impact rating is C. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

#### **Carbon emissions**

An average household produces	6 tonnes of CO2
This property produces	2.7 tonnes of CO2
This property's potential production	1.2 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

### Steps you could take to save energy

Do I need to follow these steps in order?

#### Step 1: Floor insulation (suspended floor)

Typical installation cost	£800 - £1,200
Typical yearly saving	£37
Potential rating after completing step 1	74 C

#### Step 2: Solar water heating

Typical installation cost	£4,000 - £6,000
Typical yearly saving	£72
Potential rating after completing steps 1 and 2	76 C

#### Step 3: Solar photovoltaic panels, 2.5 kWp

Typical installation cost	£3,500 - £5,500
Typical yearly saving	£352
Potential rating after completing steps 1 to 3	88 B

#### Advice on making energy saving improvements

Get detailed recommendations and cost estimates

#### Who to contact about this certificate

#### Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Philip Tallon
Telephone	07399201229
Email	ptepcs@gmail.com

#### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Stroma Certification Ltd
Assessor's ID	STRO034636
Telephone	0330 124 9660
Email	certification@stroma.com

#### About this assessment

Assessor's declaration	No related party
Date of assessment	24 January 2022
Date of certificate	24 January 2022
Type of assessment	► <u>RdSAP</u>

## Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at <a href="mailto:mhclg.digital-services@communities.gov.uk">mhclg.digital-services@communities.gov.uk</a> or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

Certificate number <u>4000-6268-0022-5024-3103 (/energy-</u>

certificate/4000-6268-0022-5024-3103)

Valid until 26 September 2030

Certificate number

8802-4167-7329-2626-5203 (/energy-certificate/8802-4167-7329-2626-5203)

**Expired on** 

25 February 2020



Help (/help) Accessibility (/accessibility-statement) Cookies (/cookies)

Give feedback (https://forms.office.com/e/KX25htGMX5)

Service performance (/service-performance)

#### **OGL**

All content is available under the <u>Open Government</u> <u>Licence v3.0 (https://www.nationalarchives.gov.uk/doc/opengovernment-licence/version/3/)</u>, except where otherwise stated



© Crown copyright (https://www.nationalarchives.gov.uk/information-management/reusing-public-sector-information/uk-government-licensing-framework/crown-copyright/)